

Antivirus/Antimalware, Mitigation M0949 - ICS

By Authorization Enforcement

Archived: 2026-04-02 12:04:36 UTC

Use signatures or heuristics to detect malicious software. Within industrial control environments, antivirus/antimalware installations should be limited to assets that are not involved in critical or real-time operations. To minimize the impact to system availability, all products should first be validated within a representative test environment before deployment to production systems. [\[1\]](#)

ID: M0949

Security Controls: IEC 62443-3-3:2013 - SR 3.2, IEC 62443-4-2:2019 - CR 3.2, NIST SP 800-53 Rev. 4 - SI-3, NIST SP 800-53 Rev. 5 - SI-3

Version: 1.0

Created: 11 June 2019

Last Modified: 16 April 2025

Source: <https://attack.mitre.org/mitigations/M0949>